

**ADDENDUM No. 3
TO APPROVED PLANS AND SPECIFICATIONS
August 21, 2009**



Re: Letting of August 21, 2009

ADDENDUM

<u>No.</u>	<u>CN/PROJECT No.</u>	<u>COUNTY</u>	<u>ISSUE DATE</u>
1.	6100020/HSIP-040-1(134)46 A300071/HSIP-040(84)184	McKinley Bernalillo	8/18/09
2.	A300071/HSIP-040(84)184	Bernalillo	8/21/09
3.	A300071/HSIP-040(84)184	Bernalillo	8/21/09

A300071/HSIP-040(84)184

YOU ARE HEREBY ADVISED OF THE FOLLOWING:

Addenda No. 2 has been deleted from this contract.

The Bid Opening for **CN A300071** has been delayed until **August 25, 2009**. This project will be incorporated into an August 25, 2009 Letting as Call No. 1. The Bid Opening will be held at the New Mexico Department of Transportation's General Office Training Rooms, 1120 Cerrillos Road, Santa Fe, New Mexico at **11:00 A.M.**

For **Internet Bidders Only**, Electronic Bid File(s) are available in Bid Express for your internet bid submittal. Electronic Bid File(s) shall be generated from the **August 25, 2009 Letting**. Electronic Bid File(s) for the August 21, 2009 Letting are no longer valid.

For **Paper Bidders Only**, Required Documents for Bid Submittal advertised and distributed for the August 21, 2009 Letting will be accepted for this project.

Reference is made to the Performance Specifications for Durable Permanent Wet Reflective Pavement Striping and Striping Warranty (7/17/09). Payment for contrast paint shall be incidental to the 6" all weather Retro-Reflective Striping that is placed on the project.

Reference is made to the Performance Specifications for Durable Permanent Wet Reflective Pavement Striping and Striping Warranty (7/17/09). The NMDOT will not exclude the warranty which is specified in the project specifications and in Addenda No. 1 dated August 18, 2009, in areas in which grooving of the pavement is not permissible (i.e. bridges and portion on I-40 East of the Carnuel Interchange for approximately ½ mile in each direction).

Reference is made to Addenda No. 1 for CN A300071 on the Performance Specifications for Durable Permanent Wet Reflective Pavement Striping and Striping Warranty (7/17/09), Subsection 2.2.1 – Performance Criteria. A contrast area of no less than 1" is required on **each** side of the stripe.

Reference is made to the Striping Legend on Sheets 7-1 thru 7-14 of the plans. The 4" stripe shown for the solid white stripe, dashed white (10' Stripe/30' Gap), and solid yellow stripe has been deleted and replaced with 6" stripe. The quantities shown on Sheet 7-17 of the plans reflect 6" striping and are therefore correct.

**Gary L.J. Giron, Cabinet Secretary
New Mexico Department of Transportation**

GG:JM