

**ADDENDUM No. 3
TO APPROVED PLANS AND SPECIFICATIONS
October 13, 2009**



Re: Letting of October 16, 2009

ADDENDUM

<u>No.</u>	<u>CN/PROJECT No.</u>	<u>COUNTY</u>	<u>ISSUE DATE</u>
1.	G5b75/GRSS-IRES-491-1(13)67	San Juan	9/18/09
2.	4068/IM-025-1(93) 5100140/HSIP-025-4(143)263 3787/EBS-TPM-1513(16)12	Dona Ana Santa Fe Rio Arriba	10/08/09
3.	G2211/AC-GRIP-(TPM)-011-1(210)12 3127/TPA-TPE-TPO-001-5(15)01	Luna San Miguel	10/13/09

G2211/AC-GRIP-(TPM)-011-1(210)12 - Attachment

YOU ARE HEREBY ADVISED OF THE FOLLOWING:

Reference is made to Sheet 1-6 of the plans. General Note No. 3 has been deleted and replaced with the following:

Removal of Surfacing: All removed surfacing shall be removed by milling. Completely mill the existing bridge approach asphalt surfacing within the limits of reconstruction. Upon removal of the detour, completely mill the detour pavement. Do not allow the millings from any milled surface to be mixed with the underlying base course. Sawcut at each limit of surfacing removal so that a neat line cut may be achieved. Haul and stockpile all milled asphalt pavement to its designated location. Reference is made to General Note No. 5.

Reference is made to Sheet 1-6 of the plans. General Note No. 5 has been deleted and replaced with the following:

Salvageable Material: Use extreme care when removing and hauling and stockpiling salvageable material to the designated areas. Perform material drop-offs during normal business hours which are Monday thru Friday, 7:00 am to 3:30 pm. Coordinate deliveries with Doug Turner, (575) 544-6611. Salvageable material damaged by the Contractor's negligence shall be repaired or replaced by the Contractor at his expense.

Haul the following salvageable items to the Deming patrol yard located at 2912 East Pine Street, Deming, NM:

- All detour drainage pipes and end sections
- All existing riprap stone
- All existing bridge rail
- All existing guard rail posts

Haul the following salvageable material to the Department's Columbus storage yard. The Columbus storage yard is located at the intersection of Taft St. and J. Carreon St. in Columbus, NM:

ADDENDUM No. 3
October 13, 2009
Page 2

- All milled detour pavement

Haul and stockpile the following salvageable material on NM 9 at mile marker 89.2:

- All detour base course
- All removed mainline milled surfacing from the bridge approaches

The quantity for Item No. 601110 – Removal of Surfacing has been revised. The estimated quantity is indicated below.

Bid Schedule Sheet 2 revised under the date of 10/13/09 is attached. Please incorporate this sheet into your contract assembly. The following is a summary of the item and quantity changes.

SECTION 0001 Roadway

<u>Item No.</u>	<u>Description</u>	<u>Previous Quantity</u>	<u>New Quantity</u>	
601110	Removal of Surfacing	4,365	6,502	S.Y.

3127/TPA-TPE-TPO-001-5(15)01 - Attachment

YOU ARE HEREBY ADVISED OF THE FOLLOWING:

Reference is made to the Water Line Summary of Quantities Table shown on Sheet 11-2 of the plans. The Water Line shall be 8 inch PVC C900.

The Notice to Contractors for Itemized List – Water System (9/16/09) has been deleted and replaced with the Notice to Contractors for Itemized List – Water System (10/13/09). The **attached** Notice to Contractors is for your information and inclusion into your contract assembly.

Gary L.J. Giron, Cabinet Secretary
New Mexico Department of Transportation

GG:JM

PROJECT(S) : AC-GRIP- (TPM) -011-1(210)12

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0100	416000 MINOR PAVEMENT	8250.000 S.Y.
0110	570176 73"SX55"R (NOMINAL) CULVERT PIPE ARCH	518.000 L.F.
0120	570177 73"SX55"R (NOMINAL) CULVERT PIPE ARCH END SECTION	7.000 EACH
0130	601000 REMOVAL OF STRUCTURES AND OBSTRUCTIONS	LUMP	LUMP	.	.	.
0140	601110 REMOVAL OF SURFACING	6502.000 S.Y.
0150	603262 COMPOSTED MULCH SOCKS	4840.000 L.F.
0160	603280 SWPPP MANAGEMENT	LUMP	LUMP	.	.	.
0170	606000 METAL BARRIER W-BEAM	1025.000 L.F.
0180	606010 METAL BARRIER THRIE BEAM	62.500 L.F.
0190	606050 METAL BARRIER END TREATMENT (ANCHORAGE)	4.000 EACH

NOTICE TO CONTRACTORS
ITEMIZED LIST – WATER SYSTEM
CN 3127 / TPA-TPE-TP0-001-5(15)01
October 13, 2009



An itemized list which includes all WATER SYSTEM items is required on this project. The itemized list shall be submitted at the Pre-Construction Conference.

The total Lump Sum costs derived from the completed itemized list shall be entered in the Bid Schedule for the following bid item:

Item Number 663206 – WATER SYSTEM (LUMP SUM)

The total amount bid for this Lump Sum item shall reflect all costs associated with the completion of the WATER SYSTEM. Only the total Lump Sum item price submitted in the Bid Schedule will be considered.

All itemized prices must equal the total Lump Sum price submitted in the Bid Schedule. If there are any mathematical errors or omissions, mathematical unbalancing, and material unbalancing in the completed itemized list, no adjustment will be made to the Lump Sum totals as indicated in the Bid Schedule.

The Contractor shall submit the completed itemized list to the Project Manager at the Pre-Construction Conference. The itemized list will be used to determine payment to the Contractor for any change orders involving this work.

ITEMIZED LIST (WATER SYSTEM)
(Includes all items defined in the contract)

LINE ITEM	ITEM DESCRIPTION	UNIT	EST. QTY.	UNIT PRICE	TOTAL PRICE
WATER LINE					
1	8 INCH PVC C900 CL. 150 WATERLINE IS COMMON TRENCH WITH STS COMPLETE IN PLACE INCLUDING FITTINGS, TESTING, DISINFECTION, MARKER TAPE, AND EMDS	LF	1620		
2	8 INCH PVC C900 CL. 150 WATERLINE IS COMMON TRENCH WITH SAS COMPLETE IN PLACE INCLUDING FITTINGS, TESTING, DISINFECTION, MARKER TAPE, AND EMDS	LF	905		
3	8 INCH PVC C900 CL. 150 WATERLINE IS COMMON TRENCH WITH EFFLUENT REUSE COMPLETE IN PLACE INCLUDING TRECHING, BACKFILL, FITTINGS, TESTING, DISINFECTION, MARKER TAPE, AND EMDS	LF	160		
4	8 INCH PVC C900 CL. 150 WATERLINE COMPLETE IN PLACE INCLUDING FITTINGS, TESTING, DISINFECTION, MARKER TAPE, AND EMDS	LF	280		
5	8 INCH GATE VALVE COMPLETE IN PLACE INCLUDING VALVE BOX, EXCAVATION, BACKFILL, AND DISINFECTION	EA	11		
6	2 INCH AIR & VACUUM RELEASE VALVE AND VAULT, COMPLETE IN PLACE INCLUDING FITTINGS, EXCAVATION, BACKFILL, TESTING, AND DISINFECTION	EA	4		

7	¾-2 INCH PE SERVICE LINE COMPLETE IN PLACE INCLUDING EXCAVATION, BACKFILLING, AND DISINFECTION	LF	360		
8	RECONNECT EXISTING ¾" – 2" SERVICE CONNECTIONS TO NEW WATER LINE INCLUDING FITTINGS, EXCAVATION, BACKFILL, AND DISINFECTION	EA	12		
9	RECONNECT EXISTING WATERLINE TO NEW WATER LINE INCLUDING FITTINGS, EXCAVATION, BACKFILLING, AND DISINFECTION	EA	10		
EFFLUENT REUSE LINE					
10	10 INCH PVC C900 CL. 200 EFFLUENT REUSE LINE IN COMMON TRENCH WITH STS COMPLETE IN PLACE INCLUDING FITTINGS, TESTING, TESTING DISINFECTION, MARKER TAPE, AND EMDS	LF	1350		
11	10 INCH PVC C900 CL. 200 EFFLUENT REUSE LINE IN COMMON TRENCH WITH SAS COMPLETE IN PLACE INCLUDING FITTINGS, TESTING, DISINFECTION, MARKER TAPE, AND EMDS	LF	905		
12	10 INCH PVC C900 CL. 200 EFFLUENT REUSE LINE, COMPLETE IN PLACE INCLUDING TRENCHING, BACKFILL, COMPACTION, FITTINGS, TESTING, DISINFECTION, MARKER TAPE, AND EMDS	LF	300		
13	10 INCH GATE VALVE COMPLETE IN PLACE INCLUDING VALVE BOX, EXCAVATION, BACKFILLING, AND DISINFECTION	EA	7		

14	2 INCH AIR & VACUUM RELEASE VALVE AND VAULT, COMPLETE IN PLACE INCLUDING FITTINGS, EXCAVATION, BACKFILL, TESTING, AND DISINFECTION	EA	2		
15	RECONNECT EXISTING EFFLUENT REUSE LINE TO NEW EFFLUENT REUSE LINE INCLUDING FITTINGS, EXCAVATION, BACKFILL, AND DISINFECTION	EA	2		
WATER SYSTEM (LUMP SUM) = (Sum of Line Items 1 thru 15)					\$